

Declaration of Compliance

Business Operator

Vikan A/S
Rævevej 1
DK-7800 Skive
(+45) 96 14 26 00

Productnaam

Reserveonderdeel haak voor 1011x, 1012x & 1014x, Zwart

Item Number

10049



Plastic Material

Polyamide (nylon), 98 %

EU Compliance

Regulation (EC) No 1935/2004

In accordance with EU Commission Regulation no. 1935/2004 article 3, 11(5), 15 and 17 the product is intended for food contact. The product is marked with the "glass & fork" symbol on the packaging or on the product itself through moulding.



AP(89)1

All pigments in the masterbatch comply with resolution AP 89(1)

Regulation (EC) No 2023/2006

The product is produced according to EU Commission Regulation no. 2023/2006 of 22. December 2006 on good manufacturing practices for materials and articles intended to come into contact with food (GMP).

Regulation (EU) No 10/2011

Monomers and intentionally added additives used to manufacture this product are listed in Annex I of Commission Regulation (EU) No. 10/2011 of 14. January 2011 on plastic materials and articles intended to come into contact with foodstuffs. Subsequent amendments up to (EU) 2023/1442 are included.

Monomers and/or additives with specific migration limit (SML) are used. The substances with a SML will not migrate in quantities that will exceed the SML, under the specified conditions of use. Upon request we will supply relevant information regarding these substances on a confidential basis.

Vikan A/S does not use multi-layer materials or articles with a functional barrier.

Regulations (EC) No 1333/2008 and (EC) No 1334/2008

This material contains intentionally added "dual use" additives for which restrictions or purity criteria are in place in accordance with Regulations (EC) 1333/2008 and (EC) 1334/2008. Upon request we will supply relevant information regarding these substances on a confidential basis.



US FDA Compliance

All raw materials in this product are in compliance with FDA (Food and Drug Administration in the USA) 21 CFR parts 170 to 199.

The polymers and additives complies with FDA 21 CFR part 174, 175, 176, 177, 178, 181, 182, 184, or 186. Additives are cleared according to FDA 21 CFR Part 178 (Indirect food additives), are generally recognised as safe (GRAS), are prior-sanctioned food ingredients, or are cleared on basis of regulations for food additives of before 1958.

The nylon material complies with the requirements of FDA (Food and Drug Administration in the USA) 21 CFR 177.1500 "Nylon resins".

UK Compliance

The product complies with The Materials and Articles in Contact with Food (Amendment) (EU Exit) Regulations 2019 No. 704.

Danish Compliance

The product complies with the Danish consolidation Act no. 681 of 25/05/2020.

Migration analysis plastics

Samples of the product, or a similar product made from identical plastic material, have been tested for overall migration according to the test conditions specified in (EU) 10/2011, and the article comply with the overall migration limit of 10 mg/dm² or 60 mg/kg.

Test conditions for overall migration were OM3 (2 h at 70 °C)

Food simulants used for overall migration were 10 % ethanol (simulant A), 3 % acetic acid (simulant B) and olive oil (simulant D2).

Compliance with specific migration limits, and other restrictions, has been documented through testing, calculation or simulation.

Max ratio of food contact surface area to volume 2.1 dm²/100 ml

Food contact types

The product is suitable for contact with the following types of food under the intended and foreseeable conditions of use:

- Aqueous
- Acidic
- Alcoholic
- Fatty
- Dry

Food contact usage time and temperature

Any food contact conditions up to 40 °C for 30 min.

Non-food contact usage temperature

Minimum temperature:
Maximum temperature: 80 °C



General

Equipment should be cleaned, disinfected and sterilised, as appropriate to its intended use, before use.

It is also important to clean, disinfect and sterilise equipment as appropriate after use, using the appropriate decontamination chemicals, concentrations, times and temperatures.

Appropriate equipment decontamination will minimise the risk of microbial growth and cross contamination and will maximise the efficiency and durability of the equipment.

Recommended sterilisation temperature (Autoclave): 121 °C

We will make the relevant background documentation available to the competent authorities, at their request.

Vikan A/S is registered with the Danish Veterinary and Food Administration (DVFA), and our mandatory Own Control System is subject to inspection by the DVFA.

Date

2023-08-22

Made By

Steen Rolander Nielsen
Group Technical Manager • Product Management and Development